



- NOTES:
- 1.) ALL DIRTY WIREWAY (DX) TO BE 1"W X 3"H AND GRAY IN COLOR.
 - 2.) ALL CLEAN WIREWAY (CX) TO BE 1"W X 3"H AND WHITE IN COLOR.

| | | | | |
|------|-------|----------------|----------------------------------|------|
| 17 | CR1 | 700-SH25VA25 | RELAY FOR TEMP. CONTROL | 1 |
| 16 | | 1492-JG4 | GROUNDING TERMINAL BLOCKS | 2 |
| 15 | | 1492-J4 | CONTROL TERMINAL BLOCKS | 8 |
| 14 | | 1492-EA35 | END ANCHOR | 6 |
| 13 | K2 | 100S-C30DJ14C | 30A, 3P, MCS SAFETY CONTACTOR | 1 |
| 12 | SR1 | 440R-N23114 | SAFETY RELAY FOR 4M DRIVE | 1 |
| 11 | VF D1 | 22F-D2P5N103 | POWER FLEX 4M DRIVE | 1 |
| 10 | SR2 | 440R-N23132 | SAFETY RELAY FOR 40P DRIVE | 1 |
| 9 | VF D2 | 22D-D2P3N104 | POWERFLEX 40P DRIVE | 1 |
| 8 | FDS | 194R-D32-1753 | 60A FUSED DISCONNECT | 1 |
| 8 | FDS | 194R-C30-1753 | 30A FUSED DISCONNECT | 1 |
| 8 | CB | 140UE-H2EA-C32 | 4" FRAME CIRCUIT BREAKER | 1 |
| 8 | CB | 140U-H2C3-C30 | 4" FRAME CIRCUIT BREAKER | 1 |
| 7 | K1 | 100-C40DJ200 | CONTRACTOR, 37A, D.C. | 1 |
| 7 | K1 | 100-C30DJ10 | CONTRACTOR, 30A, D.C. | 1 |
| 6 | CB2 | 1489-A3C070 | 3P CIRCUIT BREAKER | 1 |
| 5 | PS1 | 1606-XLP90E-2 | POWER SUPPLY | 1 |
| 4 | CB1 | 1489-A2D100 | 2P CIRCUIT BREAKER | 1 |
| 3 | CBL1 | 1763-NC01 | CABLE | 1 |
| 2 | PLC1 | 1763-L16BBB | MICROLOGIX D.C. POWER CONTROLLER | 1 |
| 1 | | CP3024 | ZINC PLATED SUBPLATE, (HOFFMANN) | 1 |
| ITEM | I.D. | PART NUMBER | DESCRIPTION | QTY. |

| | | | | |
|---------------------------------|--|--|-----------------|--------------|
| Reference | | | CCBB DEMO | |
| Revision | | | SUBPLATE LAYOUT | |
| Release | | | | |
| 1 | | | | |
| 4-18-08 | | | | |
| Dimensions Apply Before Release | | | | |
| Tolerances in Inches | | | | |
| Otherwise Specified | | | | |
| 2 Place Decimal | | | | |
| 3 Place Decimal | | | | |
| Angles ±1° | | | | |
| Refer. Book | | | | |
| Dr. LEN DAMS | | | Date 4-12-08 | Sheet 2 of 2 |
| Chkd. A. DAVIS | | | Date 4-18-08 | |
| Appd. A. DAVIS | | | Date 4-18-08 | |
| | | | Dwg Size | 31022-466 |

SUBPLATE LAYOUT